



Operating Parameters for Desalination					
Desalination Method	TDS Conc.	Operating Temp.			
	(mg/l)	(°C)			
Thermal Separation	30,000 ~ 500,000	3 <mark>5 ~ 120</mark>			
Centuries Old Method, Still Widely Applied, Mainly Overseas, Expensive					
Reverse Osmosis	500 ~ 50,000	0~40			
Renewed Interest in 1980's, Low Energy Requirements, Less Expensive					
Electro Dialysis	500 ~ 3,000	0 ~ 65			
Cost Competitive with RO i					
The Lowest Operating Te Freezing Temperature	emperature for RO and	ED is Above-			















Typical Onit Cost	UI Desait	Cu mater
Seawater (SW):		EQ.
Large Plants (Over 10 MGD)	1.52 - 3.80	\$/K Gallons
<b>Medium</b> (1 - 10 MGD)	3.80 - 5.70	\$/K Gallons
Small (Less than 1 MGD)	Over 5.70	\$/K Gallons
Brackish Water (BW)	0.40 - 3.80	\$/K Gallons
	Adil A. B	ushnak – Bushnak Water Group, Je



## Desalination Cost Reductions

- Economy of Scale
- Larger Plant Capacity/Unit Size Due to availability of High-Pressure Pumps & Large Turbines for Energy Recovery.
- Common Size will range from 25 75 MGD containing 10 20 units.











## Desalination Cost Reductions O&M Cost Reduction



- Mainly from Reduction in Manpower needed in the larger plants
- Smaller savings from Decrease in the Membrane Replacement Costs & Chemicals needed for Pre-Treatment



## Desalination Cost Reductions

## Capital Cost Reductions

- Shared Infrastructure with the Existing
   Power Plants
- Increased Life Span Due to: – Improved Building Materials
  - Use of More Mature Technologies
- Lower Financing Cost – Lower Financing Rates
  - Lowered Risk Factor in Project Financing

	Well Water, Not Collocated; Needs ½ mile outfall pipe; TDS: 3000 mg/l; Pretreatment: Zconation & Granular Media Filtration; RO System: 75% Energy Recovery; Financing @ 6% for 20 Years; Electricity @ 8 cent/kWh.		Estuary Water; Not C influent/outflow facil mg/l; Pretreatment: I 60% Energy Recover for 20 Years; Electric	ollocated; Needs ities; TDS: 10,000 MF; RO system: y; Financing @ 6' ity @ 8 cent/kWh
	\$/gal/day	\$/K gal	\$/gal/day	\$/K gal
Pretreatment	0.05	0.01	0.66	0.25
Desalting	0.93	0.92	1.13	1.19
Intake/Outfall etc.	0.44		0.5	0.01
Indirect Capital \$	0.46		0.73	1.4 1
Capital Recovery		0.44		0.71
TOTAL, \$/K gal	1.83	1.37	3.02	2.17
TOTAL. \$/AF		446		707

SW Desalina	tion Cost	Compa	arison – 10	MGD
	Collocated, Use the same influent/ Effluent facilities; TDS: 32,000 mg/l; Protreatment. MF; 40% Encorgy Recovery; Financing @ 6% for 20 Years; Electricity @ 4 cent/kWh.		Not-Collocated; Needs in facilities; TDS: 32,000 m MF; Latest Energy Recor place; Concentrate disp discharge 2 miles from s 6% for 20 years; Electric	nfluent/outfall g/l; Pretreatment; very System in soal: Ocean shore; Financing @ ity: 8 cent/kWh.
	\$/gal/Day	\$/K gal	\$/gal/Day	\$/K gal
Pretreatment	0.66	0.25	0.66	0.25
Desalting	1.43	1.09	1.54	1.40
Intake/Outfall etc.	0.12		0.69	0.01
Indirect Capital \$	0.71		0.92	A 1 2 IMP
Capital Recovery		0.69		0.90
TOTAL, \$/K gal	2.93	2.03	3.81	2.56
TOTAL, \$/AF		661		834

Cost Reduction Comparison				
(Two 5.3 MGD RO Desalination Plants)				
	Canary Island 1991	Israel 2003		
<b>Capital Cost</b>	\$20 million	\$20 million		
	\$1.14/K Gal 31% (@ 8% for 20 Years)	\$1.02/K Gal 38% (@6.5% for 20 Years)		
Energy Cost	\$1.67/K Gal 45% (5.5 kWh/CM)	\$0.91/K Gal 33% (4 kWh/CM)		
O&M Cost	\$0.91/K Gal 24%	\$0.80/K Gal 29%		
Total cost	\$3.72/K Gal	\$2.73/K Gal		



Tampa Bay De	salination Planters CA Desalimation Task Force
A Footprint i	n Desalination
Capacity	25 MGD (~ 95,000 m³/day)
Sea Water TDS (mg/L)	18,500 – 30,500 mg/L (Avg. 26,000 mg/L)
Pretreatment	Two Stage Sand Filtration
Recovery Rate	60%
Fresh Water Quality	< 500 mg/L
No. of Trains	7 @ ~ 16,000 m³/day
<b>Energy Consumption</b>	11.2 kWh/1,000 gal (~3 kWh/m <sup>3</sup> )
Energy Cost	4 cents/kWh
Water Cost	< \$2/1,000 gal (<\$0.53/m <sup>3</sup> ) (<\$652/AF)

California SV	V Desalination Experience
Aı	n Expensive Start 📩 📰
<ul> <li>Chevron's Gaviota 0.4 MGD</li> </ul>	Oil & Gas Processing Plant (1987) 46 kWh/1,000 gallons \$12.2/1,000 gal
<ul> <li>City of Morro Bay ( 0.6 MGD</li> </ul>	Status: Active (1991) 27 kWh/1,000 gallons \$5.4/1,000 gal
<ul> <li>→ 1.2 MGD</li> <li>City of Santa Barba</li> </ul>	Status: Operational when Needed
6.7 MGD	20 kWh/1,000 gallons \$5.9/1,000 gal Status: Sold
<ul> <li>Monterey Bay Aqu 0.04 MGD</li> </ul>	arium (1991) \$5.5/1,000 gal Status: Active
<ul> <li>SCE's Santa Catali 0.13 MGD</li> </ul>	na Island RO plant (1991) \$6.1/1,000 gal

Proposed SW Desalination Plants in CA					
<u>Agency</u> <u>Capa</u> (MGI	<u>city</u> ))	<u>Capital Cost</u> (million, \$)	<u>Product</u> (\$/k gal)	ion Cost* (\$/AF)	
West Basin	20	130	2.77	904	
SDCWA	50	272	2.77	909	
Orange County Municipal WD	25	114 - 140	2.63 - 3.09 86	9 60 - 1,007	
Long Beach Water District	9	62 92	2.18 – 3.5 71	9 1 - 1,171	
LADWP	12	70	3.17	1,033	
* Before any subsidy from	om MW	D			





